

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/028/26	Model No.: KMCRQ-5	Date: 05-04-2026
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 028/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01351 To 1400	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01351 To 1400 and removed from the Lot/Batch							
1351	Pass	1352	Pass	1353	Pass	1354	Pass
1355	Pass	1356	Pass	1357	Pass	1358	Pass
1359	Pass	1360	Pass	1361	Pass	1362	Pass
1363	Pass	1364	Pass	1365	Pass	1366	Pass
1367	Pass	1368	Pass	1369	Pass	1370	Pass
1371	Pass	1372	Pass	1373	Pass	1374	Pass
1375	Pass	1376	Pass	1377	Pass	1378	Pass
1379	Pass	1380	Pass	1381	Pass	1382	Pass
1383	Pass	1384	Pass	1385	Pass	1386	Pass
1387	Pass	1388	Pass	1389	Pass	1390	Pass
1391	Pass	1392	Pass	1393	Pass	1394	Pass
1395	Pass	1396	Pass	1397	Pass	1398	Pass
1399	Pass	1400	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory