

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/083/26

Model No.: KFKHQ-6

Date: 04-06-2026

Type and Capacity of Extinguisher : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.

Batch Number : KFKHQ6 083/26

Batch Quantity : 10 Nos.

Serial Numbers : 00821 To 830

Month of Manufacturing : Jun/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
821	Pass	822	Pass	823	Pass	824	Pass
825	Pass	826	Pass	827	Pass	828	Pass
829	Pass	830	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**