

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/080/26	Model No.: KFKHQ-6	Date: 27-05-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 080/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00791 To 800 And 795A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 795A and removed from the Lot/Batch							
791	Pass	792	Pass	793	Pass	794	Pass
795	Pass	796	Pass	797	Pass	798	Pass
799	Pass	800	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory