

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/081/26	Model No.: KFKHQ-6	Date: 29-05-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 081/26	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00801 To 810	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
801	Pass	802	Pass	803	Pass	804	Pass
805	Pass	806	Pass	807	Pass	808	Pass
809	Pass	810	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory