

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/080/26	Model No.: KFKHQ-6	Date: 29-05-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 080/26	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00791 To 800	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
791	Pass	792	Pass	793	Pass	794	Pass
795	Pass	796	Pass	797	Pass	798	Pass
799	Pass	800	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory