

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/034/26	Model No.: KMCRQ-10	Date: 09-04-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 034/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00331 To 340	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00331 To 340 and removed from the Lot/Batch							
331	Pass	332	Pass	333	Pass	334	Pass
335	Pass	336	Pass	337	Pass	338	Pass
339	Pass	340	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory