

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/113/26	Model No.: MARQ-6-40%	Date: 26-04-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 113/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 11201 To 11300 And 11205A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 11205A and removed from the Lot/Batch							
11201	Pass	11202	Pass	11203	Pass	11204	Pass
11205	Pass	11206	Pass	11207	Pass	11208	Pass
11209	Pass	11210	Pass	11211	Pass	11212	Pass
11213	Pass	11214	Pass	11215	Pass	11216	Pass
11217	Pass	11218	Pass	11219	Pass	11220	Pass
11221	Pass	11222	Pass	11223	Pass	11224	Pass
11225	Pass	11226	Pass	11227	Pass	11228	Pass
11229	Pass	11230	Pass	11231	Pass	11232	Pass
11233	Pass	11234	Pass	11235	Pass	11236	Pass
11237	Pass	11238	Pass	11239	Pass	11240	Pass
11241	Pass	11242	Pass	11243	Pass	11244	Pass
11245	Pass	11246	Pass	11247	Pass	11248	Pass
11249	Pass	11250	Pass	11251	Pass	11252	Pass
11253	Pass	11254	Pass	11255	Pass	11256	Pass
11257	Pass	11258	Pass	11259	Pass	11260	Pass
11261	Pass	11262	Pass	11263	Pass	11264	Pass
11265	Pass	11266	Pass	11267	Pass	11268	Pass
11269	Pass	11270	Pass	11271	Pass	11272	Pass
11273	Pass	11274	Pass	11275	Pass	11276	Pass
11277	Pass	11278	Pass	11279	Pass	11280	Pass
11281	Pass	11282	Pass	11283	Pass	11284	Pass
11285	Pass	11286	Pass	11287	Pass	11288	Pass
11289	Pass	11290	Pass	11291	Pass	11292	Pass
11293	Pass	11294	Pass	11295	Pass	11296	Pass
11297	Pass	11298	Pass	11299	Pass	11300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory