

HELIUM LEAK DETECTION TEST

TC No.: HLD/CA4/MRI/HQ/005/26	Model No.: KCAHQMRI-4-FE36	Date: 04-06-2026
Type and Capacity of Extinguisher	: KCAHQMRI-4-FE36-Kanex Clean Agent Fire Extinguisher Cap. 4 Kg. for MRI Room	
Batch Number	: KCAHQMRI4 005/26	
Batch Quantity	: 5 Nos.	
Serial Numbers	: 00021 To 25	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
21	Pass	22	Pass	23	Pass	24	Pass
25	Pass						

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory