

HELIUM LEAK DETECTION TEST

TC No.: HLD/A9/K/HQ/020/26	Model No.: KFKHQ-9	Date: 16-04-2026
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 020/26	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00191 To 200	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
191	Pass	192	Pass	193	Pass	194	Pass
195	Pass	196	Pass	197	Pass	198	Pass
199	Pass	200	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory