

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/116/26	Model No.: KFARQ-6-50%	Date: 21-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 116/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 11501 To 11600 And 11505A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 11505A and removed from the Lot/Batch							
11501	Pass	11502	Pass	11503	Pass	11504	Pass
11505	Pass	11506	Pass	11507	Pass	11508	Pass
11509	Pass	11510	Pass	11511	Pass	11512	Pass
11513	Pass	11514	Pass	11515	Pass	11516	Pass
11517	Pass	11518	Pass	11519	Pass	11520	Pass
11521	Pass	11522	Pass	11523	Pass	11524	Pass
11525	Pass	11526	Pass	11527	Pass	11528	Pass
11529	Pass	11530	Pass	11531	Pass	11532	Pass
11533	Pass	11534	Pass	11535	Pass	11536	Pass
11537	Pass	11538	Pass	11539	Pass	11540	Pass
11541	Pass	11542	Pass	11543	Pass	11544	Pass
11545	Pass	11546	Pass	11547	Pass	11548	Pass
11549	Pass	11550	Pass	11551	Pass	11552	Pass
11553	Pass	11554	Pass	11555	Pass	11556	Pass
11557	Pass	11558	Pass	11559	Pass	11560	Pass
11561	Pass	11562	Pass	11563	Pass	11564	Pass
11565	Pass	11566	Pass	11567	Pass	11568	Pass
11569	Pass	11570	Pass	11571	Pass	11572	Pass
11573	Pass	11574	Pass	11575	Pass	11576	Pass
11577	Pass	11578	Pass	11579	Pass	11580	Pass
11581	Pass	11582	Pass	11583	Pass	11584	Pass
11585	Pass	11586	Pass	11587	Pass	11588	Pass
11589	Pass	11590	Pass	11591	Pass	11592	Pass
11593	Pass	11594	Pass	11595	Pass	11596	Pass
11597	Pass	11598	Pass	11599	Pass	11600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory