

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/108/26	Model No.: KFARQ-6-90%	Date: 25-04-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 108/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 10701 To 10800 And 10705A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 10705A and removed from the Lot/Batch							
10701	Pass	10702	Pass	10703	Pass	10704	Pass
10705	Pass	10706	Pass	10707	Pass	10708	Pass
10709	Pass	10710	Pass	10711	Pass	10712	Pass
10713	Pass	10714	Pass	10715	Pass	10716	Pass
10717	Pass	10718	Pass	10719	Pass	10720	Pass
10721	Pass	10722	Pass	10723	Pass	10724	Pass
10725	Pass	10726	Pass	10727	Pass	10728	Pass
10729	Pass	10730	Pass	10731	Pass	10732	Pass
10733	Pass	10734	Pass	10735	Pass	10736	Pass
10737	Pass	10738	Pass	10739	Pass	10740	Pass
10741	Pass	10742	Pass	10743	Pass	10744	Pass
10745	Pass	10746	Pass	10747	Pass	10748	Pass
10749	Pass	10750	Pass	10751	Pass	10752	Pass
10753	Pass	10754	Pass	10755	Pass	10756	Pass
10757	Pass	10758	Pass	10759	Pass	10760	Pass
10761	Pass	10762	Pass	10763	Pass	10764	Pass
10765	Pass	10766	Pass	10767	Pass	10768	Pass
10769	Pass	10770	Pass	10771	Pass	10772	Pass
10773	Pass	10774	Pass	10775	Pass	10776	Pass
10777	Pass	10778	Pass	10779	Pass	10780	Pass
10781	Pass	10782	Pass	10783	Pass	10784	Pass
10785	Pass	10786	Pass	10787	Pass	10788	Pass
10789	Pass	10790	Pass	10791	Pass	10792	Pass
10793	Pass	10794	Pass	10795	Pass	10796	Pass
10797	Pass	10798	Pass	10799	Pass	10800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory