

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/SS/HQ/003/26	Model No.: KFASSHQ-6-50%	Date: 25-05-2026
Type and Capacity of Extinguisher	: KFASSHQ-6-50%-Kanex ABC Dry Powder SS Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFASSHQ50%6 003/26	
Batch Quantity	: 21.00 Nos.	
Serial Numbers	: 00041 To 60 And 45A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 45A and removed from the Lot/Batch							
41	Pass	42	Pass	43	Pass	44	Pass
45	Pass	46	Pass	47	Pass	48	Pass
49	Pass	50	Pass	51	Pass	52	Pass
53	Pass	54	Pass	55	Pass	56	Pass
57	Pass	58	Pass	59	Pass	60	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory