

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/030/26	Model No.: MARQ-4-50%	Date: 20-03-2026
Type and Capacity of Extinguisher	: MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: MARQ50%4 030/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 02901 To 3000 And 2905A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 2905A and removed from the Lot/Batch							
2901	Pass	2902	Pass	2903	Pass	2904	Pass
2905	Pass	2906	Pass	2907	Pass	2908	Pass
2909	Pass	2910	Pass	2911	Pass	2912	Pass
2913	Pass	2914	Pass	2915	Pass	2916	Pass
2917	Pass	2918	Pass	2919	Pass	2920	Pass
2921	Pass	2922	Pass	2923	Pass	2924	Pass
2925	Pass	2926	Pass	2927	Pass	2928	Pass
2929	Pass	2930	Pass	2931	Pass	2932	Pass
2933	Pass	2934	Pass	2935	Pass	2936	Pass
2937	Pass	2938	Pass	2939	Pass	2940	Pass
2941	Pass	2942	Pass	2943	Pass	2944	Pass
2945	Pass	2946	Pass	2947	Pass	2948	Pass
2949	Pass	2950	Pass	2951	Pass	2952	Pass
2953	Pass	2954	Pass	2955	Pass	2956	Pass
2957	Pass	2958	Pass	2959	Pass	2960	Pass
2961	Pass	2962	Pass	2963	Pass	2964	Pass
2965	Pass	2966	Pass	2967	Pass	2968	Pass
2969	Pass	2970	Pass	2971	Pass	2972	Pass
2973	Pass	2974	Pass	2975	Pass	2976	Pass
2977	Pass	2978	Pass	2979	Pass	2980	Pass
2981	Pass	2982	Pass	2983	Pass	2984	Pass
2985	Pass	2986	Pass	2987	Pass	2988	Pass
2989	Pass	2990	Pass	2991	Pass	2992	Pass
2993	Pass	2994	Pass	2995	Pass	2996	Pass
2997	Pass	2998	Pass	2999	Pass	3000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory