

HYDRO PRESSURE TEST

TC No.: HPT/CA6/SS/RQ/010/26	Model No.: KCASSRQ-6	Date: 16-05-2026
Type and Capacity of Extinguisher	: KCASSRQ-6-Kanex SS Clean Agent Fire Extinguisher Cap. 6 Kg	
Batch Number	: KCASSRQ6 010/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00091 To 100 And 95A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 95A and removed from the Lot/Batch							
91	Pass	92	Pass	93	Pass	94	Pass
95	Pass	96	Pass	97	Pass	98	Pass
99	Pass	100	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory