

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/029/26	Model No.: MARQ-4-50%	Date: 20-03-2026
Type and Capacity of Extinguisher	: MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: MARQ50%4 029/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 02801 To 2900 And 2805A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 2805A and removed from the Lot/Batch							
2801	Pass	2802	Pass	2803	Pass	2804	Pass
2805	Pass	2806	Pass	2807	Pass	2808	Pass
2809	Pass	2810	Pass	2811	Pass	2812	Pass
2813	Pass	2814	Pass	2815	Pass	2816	Pass
2817	Pass	2818	Pass	2819	Pass	2820	Pass
2821	Pass	2822	Pass	2823	Pass	2824	Pass
2825	Pass	2826	Pass	2827	Pass	2828	Pass
2829	Pass	2830	Pass	2831	Pass	2832	Pass
2833	Pass	2834	Pass	2835	Pass	2836	Pass
2837	Pass	2838	Pass	2839	Pass	2840	Pass
2841	Pass	2842	Pass	2843	Pass	2844	Pass
2845	Pass	2846	Pass	2847	Pass	2848	Pass
2849	Pass	2850	Pass	2851	Pass	2852	Pass
2853	Pass	2854	Pass	2855	Pass	2856	Pass
2857	Pass	2858	Pass	2859	Pass	2860	Pass
2861	Pass	2862	Pass	2863	Pass	2864	Pass
2865	Pass	2866	Pass	2867	Pass	2868	Pass
2869	Pass	2870	Pass	2871	Pass	2872	Pass
2873	Pass	2874	Pass	2875	Pass	2876	Pass
2877	Pass	2878	Pass	2879	Pass	2880	Pass
2881	Pass	2882	Pass	2883	Pass	2884	Pass
2885	Pass	2886	Pass	2887	Pass	2888	Pass
2889	Pass	2890	Pass	2891	Pass	2892	Pass
2893	Pass	2894	Pass	2895	Pass	2896	Pass
2897	Pass	2898	Pass	2899	Pass	2900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory