

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/084/26

Model No.: KFKHQ-6

Date: 07-06-2026

Type and Capacity of Extinguisher : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.

Batch Number : KFKHQ6 084/26

Batch Quantity : 10 Nos.

Serial Numbers : 00831 To 840

Month of Manufacturing : Jun/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
831	Pass	832	Pass	833	Pass	834	Pass
835	Pass	836	Pass	837	Pass	838	Pass
839	Pass	840	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**