

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/084/26	Model No.: KFKHQ-6	Date: 05-06-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 084/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00831 To 840 And 835A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 835A and removed from the Lot/Batch							
831	Pass	832	Pass	833	Pass	834	Pass
835	Pass	836	Pass	837	Pass	838	Pass
839	Pass	840	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory