

# HYDRO PRESSURE TEST

|                                   |                                                               |                  |
|-----------------------------------|---------------------------------------------------------------|------------------|
| TC No.: HPT/A9/K/HQ/017/26        | Model No.: KFKHQ-9                                            | Date: 11-04-2026 |
| Type and Capacity of Extinguisher | : KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr. |                  |
| Batch Number                      | : KFKHQ9 017/26                                               |                  |
| Batch Quantity                    | : 10.00 Nos.                                                  |                  |
| Serial Numbers                    | : 00161 To 170                                                |                  |
| Month of Manufacturing            | : Apr/26                                                      |                  |

| Sr. Nos.                                                            | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 00161 To 170 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 161                                                                 | Pass   | 162      | Pass   | 163      | Pass   | 164      | Pass   |
| 165                                                                 | Pass   | 166      | Pass   | 167      | Pass   | 168      | Pass   |
| 169                                                                 | Pass   | 170      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**