

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/230/26	Model No.: MARQ-6-50%	Date: 02-06-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 230/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 22901 To 23000 And 22905A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 22905A and removed from the Lot/Batch							
22901	Pass	22902	Pass	22903	Pass	22904	Pass
22905	Pass	22906	Pass	22907	Pass	22908	Pass
22909	Pass	22910	Pass	22911	Pass	22912	Pass
22913	Pass	22914	Pass	22915	Pass	22916	Pass
22917	Pass	22918	Pass	22919	Pass	22920	Pass
22921	Pass	22922	Pass	22923	Pass	22924	Pass
22925	Pass	22926	Pass	22927	Pass	22928	Pass
22929	Pass	22930	Pass	22931	Pass	22932	Pass
22933	Pass	22934	Pass	22935	Pass	22936	Pass
22937	Pass	22938	Pass	22939	Pass	22940	Pass
22941	Pass	22942	Pass	22943	Pass	22944	Pass
22945	Pass	22946	Pass	22947	Pass	22948	Pass
22949	Pass	22950	Pass	22951	Pass	22952	Pass
22953	Pass	22954	Pass	22955	Pass	22956	Pass
22957	Pass	22958	Pass	22959	Pass	22960	Pass
22961	Pass	22962	Pass	22963	Pass	22964	Pass
22965	Pass	22966	Pass	22967	Pass	22968	Pass
22969	Pass	22970	Pass	22971	Pass	22972	Pass
22973	Pass	22974	Pass	22975	Pass	22976	Pass
22977	Pass	22978	Pass	22979	Pass	22980	Pass
22981	Pass	22982	Pass	22983	Pass	22984	Pass
22985	Pass	22986	Pass	22987	Pass	22988	Pass
22989	Pass	22990	Pass	22991	Pass	22992	Pass
22993	Pass	22994	Pass	22995	Pass	22996	Pass
22997	Pass	22998	Pass	22999	Pass	23000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory