

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/182/26	Model No.: KFARQ-6-50%	Date: 25-05-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 182/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 18101 To 18200 And 18105A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 18105A and removed from the Lot/Batch							
18101	Pass	18102	Pass	18103	Pass	18104	Pass
18105	Pass	18106	Pass	18107	Pass	18108	Pass
18109	Pass	18110	Pass	18111	Pass	18112	Pass
18113	Pass	18114	Pass	18115	Pass	18116	Pass
18117	Pass	18118	Pass	18119	Pass	18120	Pass
18121	Pass	18122	Pass	18123	Pass	18124	Pass
18125	Pass	18126	Pass	18127	Pass	18128	Pass
18129	Pass	18130	Pass	18131	Pass	18132	Pass
18133	Pass	18134	Pass	18135	Pass	18136	Pass
18137	Pass	18138	Pass	18139	Pass	18140	Pass
18141	Pass	18142	Pass	18143	Pass	18144	Pass
18145	Pass	18146	Pass	18147	Pass	18148	Pass
18149	Pass	18150	Pass	18151	Pass	18152	Pass
18153	Pass	18154	Pass	18155	Pass	18156	Pass
18157	Pass	18158	Pass	18159	Pass	18160	Pass
18161	Pass	18162	Pass	18163	Pass	18164	Pass
18165	Pass	18166	Pass	18167	Pass	18168	Pass
18169	Pass	18170	Pass	18171	Pass	18172	Pass
18173	Pass	18174	Pass	18175	Pass	18176	Pass
18177	Pass	18178	Pass	18179	Pass	18180	Pass
18181	Pass	18182	Pass	18183	Pass	18184	Pass
18185	Pass	18186	Pass	18187	Pass	18188	Pass
18189	Pass	18190	Pass	18191	Pass	18192	Pass
18193	Pass	18194	Pass	18195	Pass	18196	Pass
18197	Pass	18198	Pass	18199	Pass	18200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory