

HELIUM LEAK DETECTION TEST

TC No.: HLD/MOD10/CA/HQ/009/26	Model No.: KMCHQ-10-FE36	Date: 10-05-2026
Type and Capacity of Extinguisher	: KMCHQ-10-FE36-Kanex Modular Clean Agent Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCHQ10 009/26	
Batch Quantity	: 20 Nos.	
Serial Numbers	: 00161 To 180	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
161	Pass	162	Pass	163	Pass	164	Pass
165	Pass	166	Pass	167	Pass	168	Pass
169	Pass	170	Pass	171	Pass	172	Pass
173	Pass	174	Pass	175	Pass	176	Pass
177	Pass	178	Pass	179	Pass	180	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory