

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/054/26	Model No.: KMCRQ-10	Date: 25-04-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 054/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00531 To 540	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00531 To 540 and removed from the Lot/Batch							
531	Pass	532	Pass	533	Pass	534	Pass
535	Pass	536	Pass	537	Pass	538	Pass
539	Pass	540	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory