

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A90/RQ/101/26      | Model No.: KFARQ-6-90%                                          | Date: 24-04-2026 |
| Type and Capacity of Extinguisher | : KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ90%6 101/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 10001 To 10100 And 10005A                                     |                  |
| Month of Manufacturing            | : Apr/26                                                        |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 10005A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 10001                                                         | Pass   | 10002    | Pass   | 10003    | Pass   | 10004    | Pass   |
| 10005                                                         | Pass   | 10006    | Pass   | 10007    | Pass   | 10008    | Pass   |
| 10009                                                         | Pass   | 10010    | Pass   | 10011    | Pass   | 10012    | Pass   |
| 10013                                                         | Pass   | 10014    | Pass   | 10015    | Pass   | 10016    | Pass   |
| 10017                                                         | Pass   | 10018    | Pass   | 10019    | Pass   | 10020    | Pass   |
| 10021                                                         | Pass   | 10022    | Pass   | 10023    | Pass   | 10024    | Pass   |
| 10025                                                         | Pass   | 10026    | Pass   | 10027    | Pass   | 10028    | Pass   |
| 10029                                                         | Pass   | 10030    | Pass   | 10031    | Pass   | 10032    | Pass   |
| 10033                                                         | Pass   | 10034    | Pass   | 10035    | Pass   | 10036    | Pass   |
| 10037                                                         | Pass   | 10038    | Pass   | 10039    | Pass   | 10040    | Pass   |
| 10041                                                         | Pass   | 10042    | Pass   | 10043    | Pass   | 10044    | Pass   |
| 10045                                                         | Pass   | 10046    | Pass   | 10047    | Pass   | 10048    | Pass   |
| 10049                                                         | Pass   | 10050    | Pass   | 10051    | Pass   | 10052    | Pass   |
| 10053                                                         | Pass   | 10054    | Pass   | 10055    | Pass   | 10056    | Pass   |
| 10057                                                         | Pass   | 10058    | Pass   | 10059    | Pass   | 10060    | Pass   |
| 10061                                                         | Pass   | 10062    | Pass   | 10063    | Pass   | 10064    | Pass   |
| 10065                                                         | Pass   | 10066    | Pass   | 10067    | Pass   | 10068    | Pass   |
| 10069                                                         | Pass   | 10070    | Pass   | 10071    | Pass   | 10072    | Pass   |
| 10073                                                         | Pass   | 10074    | Pass   | 10075    | Pass   | 10076    | Pass   |
| 10077                                                         | Pass   | 10078    | Pass   | 10079    | Pass   | 10080    | Pass   |
| 10081                                                         | Pass   | 10082    | Pass   | 10083    | Pass   | 10084    | Pass   |
| 10085                                                         | Pass   | 10086    | Pass   | 10087    | Pass   | 10088    | Pass   |
| 10089                                                         | Pass   | 10090    | Pass   | 10091    | Pass   | 10092    | Pass   |
| 10093                                                         | Pass   | 10094    | Pass   | 10095    | Pass   | 10096    | Pass   |
| 10097                                                         | Pass   | 10098    | Pass   | 10099    | Pass   | 10100    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**


 SIHOR  
 (GUJARAT)

**Authorized Signatory**