

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/023/26	Model No.: MARQ-9-50%	Date: 25-05-2026
Type and Capacity of Extinguisher	: MARQ-9-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	
Batch Number	: MARQ50%9 023/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 02201 To 2300 And 2205A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 2205A and removed from the Lot/Batch							
2201	Pass	2202	Pass	2203	Pass	2204	Pass
2205	Pass	2206	Pass	2207	Pass	2208	Pass
2209	Pass	2210	Pass	2211	Pass	2212	Pass
2213	Pass	2214	Pass	2215	Pass	2216	Pass
2217	Pass	2218	Pass	2219	Pass	2220	Pass
2221	Pass	2222	Pass	2223	Pass	2224	Pass
2225	Pass	2226	Pass	2227	Pass	2228	Pass
2229	Pass	2230	Pass	2231	Pass	2232	Pass
2233	Pass	2234	Pass	2235	Pass	2236	Pass
2237	Pass	2238	Pass	2239	Pass	2240	Pass
2241	Pass	2242	Pass	2243	Pass	2244	Pass
2245	Pass	2246	Pass	2247	Pass	2248	Pass
2249	Pass	2250	Pass	2251	Pass	2252	Pass
2253	Pass	2254	Pass	2255	Pass	2256	Pass
2257	Pass	2258	Pass	2259	Pass	2260	Pass
2261	Pass	2262	Pass	2263	Pass	2264	Pass
2265	Pass	2266	Pass	2267	Pass	2268	Pass
2269	Pass	2270	Pass	2271	Pass	2272	Pass
2273	Pass	2274	Pass	2275	Pass	2276	Pass
2277	Pass	2278	Pass	2279	Pass	2280	Pass
2281	Pass	2282	Pass	2283	Pass	2284	Pass
2285	Pass	2286	Pass	2287	Pass	2288	Pass
2289	Pass	2290	Pass	2291	Pass	2292	Pass
2293	Pass	2294	Pass	2295	Pass	2296	Pass
2297	Pass	2298	Pass	2299	Pass	2300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory