

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/070/26	Model No.: KMCRQ-10	Date: 27-05-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 070/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00691 To 700	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00691 To 700 and removed from the Lot/Batch							
691	Pass	692	Pass	693	Pass	694	Pass
695	Pass	696	Pass	697	Pass	698	Pass
699	Pass	700	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory