

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/118/26	Model No.: KFARQ-6-50%	Date: 21-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 118/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 11701 To 11800 And 11705A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 11705A and removed from the Lot/Batch							
11701	Pass	11702	Pass	11703	Pass	11704	Pass
11705	Pass	11706	Pass	11707	Pass	11708	Pass
11709	Pass	11710	Pass	11711	Pass	11712	Pass
11713	Pass	11714	Pass	11715	Pass	11716	Pass
11717	Pass	11718	Pass	11719	Pass	11720	Pass
11721	Pass	11722	Pass	11723	Pass	11724	Pass
11725	Pass	11726	Pass	11727	Pass	11728	Pass
11729	Pass	11730	Pass	11731	Pass	11732	Pass
11733	Pass	11734	Pass	11735	Pass	11736	Pass
11737	Pass	11738	Pass	11739	Pass	11740	Pass
11741	Pass	11742	Pass	11743	Pass	11744	Pass
11745	Pass	11746	Pass	11747	Pass	11748	Pass
11749	Pass	11750	Pass	11751	Pass	11752	Pass
11753	Pass	11754	Pass	11755	Pass	11756	Pass
11757	Pass	11758	Pass	11759	Pass	11760	Pass
11761	Pass	11762	Pass	11763	Pass	11764	Pass
11765	Pass	11766	Pass	11767	Pass	11768	Pass
11769	Pass	11770	Pass	11771	Pass	11772	Pass
11773	Pass	11774	Pass	11775	Pass	11776	Pass
11777	Pass	11778	Pass	11779	Pass	11780	Pass
11781	Pass	11782	Pass	11783	Pass	11784	Pass
11785	Pass	11786	Pass	11787	Pass	11788	Pass
11789	Pass	11790	Pass	11791	Pass	11792	Pass
11793	Pass	11794	Pass	11795	Pass	11796	Pass
11797	Pass	11798	Pass	11799	Pass	11800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory