

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/119/26	Model No.: KFARQ-6-50%	Date: 21-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 119/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 11801 To 11900 And 11805A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 11805A and removed from the Lot/Batch							
11801	Pass	11802	Pass	11803	Pass	11804	Pass
11805	Pass	11806	Pass	11807	Pass	11808	Pass
11809	Pass	11810	Pass	11811	Pass	11812	Pass
11813	Pass	11814	Pass	11815	Pass	11816	Pass
11817	Pass	11818	Pass	11819	Pass	11820	Pass
11821	Pass	11822	Pass	11823	Pass	11824	Pass
11825	Pass	11826	Pass	11827	Pass	11828	Pass
11829	Pass	11830	Pass	11831	Pass	11832	Pass
11833	Pass	11834	Pass	11835	Pass	11836	Pass
11837	Pass	11838	Pass	11839	Pass	11840	Pass
11841	Pass	11842	Pass	11843	Pass	11844	Pass
11845	Pass	11846	Pass	11847	Pass	11848	Pass
11849	Pass	11850	Pass	11851	Pass	11852	Pass
11853	Pass	11854	Pass	11855	Pass	11856	Pass
11857	Pass	11858	Pass	11859	Pass	11860	Pass
11861	Pass	11862	Pass	11863	Pass	11864	Pass
11865	Pass	11866	Pass	11867	Pass	11868	Pass
11869	Pass	11870	Pass	11871	Pass	11872	Pass
11873	Pass	11874	Pass	11875	Pass	11876	Pass
11877	Pass	11878	Pass	11879	Pass	11880	Pass
11881	Pass	11882	Pass	11883	Pass	11884	Pass
11885	Pass	11886	Pass	11887	Pass	11888	Pass
11889	Pass	11890	Pass	11891	Pass	11892	Pass
11893	Pass	11894	Pass	11895	Pass	11896	Pass
11897	Pass	11898	Pass	11899	Pass	11900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory