

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/120/26	Model No.: KFARQ-6-50%	Date: 21-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 120/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 11901 To 12000 And 11905A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 11905A and removed from the Lot/Batch							
11901	Pass	11902	Pass	11903	Pass	11904	Pass
11905	Pass	11906	Pass	11907	Pass	11908	Pass
11909	Pass	11910	Pass	11911	Pass	11912	Pass
11913	Pass	11914	Pass	11915	Pass	11916	Pass
11917	Pass	11918	Pass	11919	Pass	11920	Pass
11921	Pass	11922	Pass	11923	Pass	11924	Pass
11925	Pass	11926	Pass	11927	Pass	11928	Pass
11929	Pass	11930	Pass	11931	Pass	11932	Pass
11933	Pass	11934	Pass	11935	Pass	11936	Pass
11937	Pass	11938	Pass	11939	Pass	11940	Pass
11941	Pass	11942	Pass	11943	Pass	11944	Pass
11945	Pass	11946	Pass	11947	Pass	11948	Pass
11949	Pass	11950	Pass	11951	Pass	11952	Pass
11953	Pass	11954	Pass	11955	Pass	11956	Pass
11957	Pass	11958	Pass	11959	Pass	11960	Pass
11961	Pass	11962	Pass	11963	Pass	11964	Pass
11965	Pass	11966	Pass	11967	Pass	11968	Pass
11969	Pass	11970	Pass	11971	Pass	11972	Pass
11973	Pass	11974	Pass	11975	Pass	11976	Pass
11977	Pass	11978	Pass	11979	Pass	11980	Pass
11981	Pass	11982	Pass	11983	Pass	11984	Pass
11985	Pass	11986	Pass	11987	Pass	11988	Pass
11989	Pass	11990	Pass	11991	Pass	11992	Pass
11993	Pass	11994	Pass	11995	Pass	11996	Pass
11997	Pass	11998	Pass	11999	Pass	12000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory