



# Warranty Certificate

Date: 15-06-2026

Manufacturer: Kanex Fire Solutions Limited.

Customer Name: Bombay Fire SafetyWarranty Start Date: 15-06-2026Warranty End Date: 14-06-2027.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

**NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.**

| Sr.No. | Type & Capacity of Extinguishers                            | Quantity | Sr. Nos.            |
|--------|-------------------------------------------------------------|----------|---------------------|
| 1      | KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr. | 2        | As Per Annexure – I |

Also certify that, all the Fire extinguishers supplied against Invoice No. **26-27/K/002273 Dated: 15-06-2026 P.O.No. Mail 15-06-2026** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.



Authorized Signatory