

HELIUM LEAK DETECTION TEST

TC No.: HLD/CA4/MRI/HQ/005/26

Model No.: KCAHQMRI-4-FE36

Date: 04-06-2026

Type and Capacity of Extinguisher : KCAHQMRI-4-FE36-Kanex Clean Agent Fire Extinguisher Cap. 4 Kg. for MRI Room

Batch Number : KCAHQMRI4 005/26

Batch Quantity : 5 Nos.

Serial Numbers : 00021 To 25

Month of Manufacturing : Jun/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
21	Pass	22	Pass	23	Pass	24	Pass
25	Pass						

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**