

HYDRO PRESSURE TEST

TC No.: HPT/CA4/MRI/HQ/005/26	Model No.: KCAHQMRI-4-FE36	Date: 02-06-2026
Type and Capacity of Extinguisher	: KCAHQMRI-4-FE36-Kanex Clean Agent Fire Extinguisher Cap. 4 Kg. for MRI Room	
Batch Number	: KCAHQMRI4 005/26	
Batch Quantity	: 6.00 Nos.	
Serial Numbers	: 00021 To 25 And 25A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25A and removed from the Lot/Batch							
21	Pass	22	Pass	23	Pass	24	Pass
25	Pass						

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory