

TC No.: F9/SP/RQ/032/26	Model No.: KFMSRQ-9	Date: 29-04-2026
Type and Capacity of Extinguisher	: KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFMSRQ9 032/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 03101 To 3200 And 3105A	
Month of Manufacturing	: Apr/26	
Date of Inspection	: 29-04-2026	

Sr. Nos.	Cl. No.	Tests and Inspection	Requirements	Sampling	Observation
1	5.1.5	Extinguishing Agent	AFFF Foam Concentration 6% Confirms to IS 4989	One	Pass
2	5.2	Propellants	The propellants for stored pressure and cartridge operated extinguishers shall be air, carbon dioxide and nitrogen.	All	Nitrogen
3	5.3.2	Filling tolerance	+5% by Volume	One	Pass
4	6.1	Hydro test of the body	Test pressure 35 bar, Hold for 2.5 Min.	All	Pass
5	7.2	Effective discharge time	Approved fire rating is 4A:144B, hence Min. duration is 15sec. Sr. No. :03101	One	55 SEC.
6	7.2	Bulk range of Discharge	Approved fire rating is 4A:144B, hence Min. bulk range is 2m. Sr. No. :03101	One	4 Mtr.
7	3.8	Percentage of Discharge	Min. 95%, Sr. No. :03101	One	95%
8	7.4.1	Retention of Charge following partial discharge	The second pressure or weight shall not be less than 75% of the first after interruption of the discharge. Sr. No. :03102	One	96%
9	7.4.2	Leakage Test	Inverted Glass Jar/ Applying Soap Solution	All	Pass
10	9.2	Construction Requirements	As per IS 15683:2018	All	Pass
11	9.2.2	Burst test of body	Burst pressure shall be 55 bar if break from body and shall be 80 bar if break from welding . Sr. No. :03105A	One	132 Bar
12	9.3	Carrying Handle	Requirements as per IS 15683:2018	All	Pass
13	9.4	Mounting Test	As per IS 15683:2018	All	Pass
14	9.5	Valves and Closures	As per IS 15683:2018	All	Pass
15	9.8	Hose Assemblies	Length of hose is 465mm and shall withstands a hydro pressure of 55 bar for at least 30 seconds.	One	56 Bar
16	9.9	Method of Operation	Max. force required to operate the valve with full hand is 200N	One	152N
17	9.10.1	Safety Locking Devices	Force required to remove safety locking device is 20N-100N	Two	42N & 47N
18	9.10.6	Safety Locking Devices	Tamper indicator shall break with force not more than 70N & other requiremet as per IS 15683:2018	Two	46N & 51N
19	10.1	Color for body	Shade No. 538(P.O. Red) of IS 5 and yellow band to be provided	All	Pass
20	--	Anticorrosive treatment & Painting	Phosphate treatment followed by Pure polyester Powder coating with DFT not less than 50μ.	All	(65-90)μ
21	10.2.1	Marking	As per IS 15683:2018	All	Pass
22	10.2.2	Operating Instructions	As per IS 15683:2018	All	Pass
23	10.2.3	Code symbols	As per IS 15683:2018	All	Pass
24	10.3	Inspection instruction	As per IS 15683:2018	All	Pass
25	Type tests	1)Resistance to Temp. changes 2)Impact test 3)Vibrations test 4)External Corrosion test 5)Internal Corrosion test 6)Intermittent discharge 7)Maximum Service Pressure 8)Crushing test 9)Pressure cycling 10) Fire performance test	As per IS 15683:2018	As per Scheme of testing	Pass
26	--	Dimensions and Completeness	Diameter: 180±5mm, Height: 575mm Approx, Thickness: 1.6mm Approx	All	Pass

Remarks: This is to certify that the Foam Stored Pressure type Fire Extinguisher of Capacity 9 ltr. meets and confirms to the requirements of IS 15683:2018.



Authorized Signatory