

HELIUM LEAK DETECTION TEST

TC No.: HLD/CA6/MRI/HQ/ 003/26

Model No.: KCAHQMRI-6-FE36

Date: 11-06-2026

Type and Capacity of Extinguisher : KCAHQMRI-6-FE36-Kanex Clean Agent Fire Extinguisher Cap. 6 Kg. for MRI Room

Batch Number : KCAHQMRI6 003/26

Batch Quantity : 5 Nos.

Serial Numbers : 00011 To 15

Month of Manufacturing : Jun/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
11	Pass	12	Pass	13	Pass	14	Pass
15	Pass						

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**