

HYDRO PRESSURE TEST

TC No.: HPT/CA6/MRI/HQ/ 003/26	Model No.: KCAHQMRI-6-FE36	Date: 09-06-2026
Type and Capacity of Extinguisher	: KCAHQMRI-6-FE36-Kanex Clean Agent Fire Extinguisher Cap. 6 Kg. for MRI Room	
Batch Number	: KCAHQMRI6 003/26	
Batch Quantity	: 6.00 Nos.	
Serial Numbers	: 00011 To 15 And 15A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15A and removed from the Lot/Batch							
11	Pass	12	Pass	13	Pass	14	Pass
15	Pass						

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory