

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/067/26	Model No.: KFARQ-4-90%	Date: 07-03-2026
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 067/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 06601 To 6700 And 6605A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 6605A and removed from the Lot/Batch							
6601	Pass	6602	Pass	6603	Pass	6604	Pass
6605	Pass	6606	Pass	6607	Pass	6608	Pass
6609	Pass	6610	Pass	6611	Pass	6612	Pass
6613	Pass	6614	Pass	6615	Pass	6616	Pass
6617	Pass	6618	Pass	6619	Pass	6620	Pass
6621	Pass	6622	Pass	6623	Pass	6624	Pass
6625	Pass	6626	Pass	6627	Pass	6628	Pass
6629	Pass	6630	Pass	6631	Pass	6632	Pass
6633	Pass	6634	Pass	6635	Pass	6636	Pass
6637	Pass	6638	Pass	6639	Pass	6640	Pass
6641	Pass	6642	Pass	6643	Pass	6644	Pass
6645	Pass	6646	Pass	6647	Pass	6648	Pass
6649	Pass	6650	Pass	6651	Pass	6652	Pass
6653	Pass	6654	Pass	6655	Pass	6656	Pass
6657	Pass	6658	Pass	6659	Pass	6660	Pass
6661	Pass	6662	Pass	6663	Pass	6664	Pass
6665	Pass	6666	Pass	6667	Pass	6668	Pass
6669	Pass	6670	Pass	6671	Pass	6672	Pass
6673	Pass	6674	Pass	6675	Pass	6676	Pass
6677	Pass	6678	Pass	6679	Pass	6680	Pass
6681	Pass	6682	Pass	6683	Pass	6684	Pass
6685	Pass	6686	Pass	6687	Pass	6688	Pass
6689	Pass	6690	Pass	6691	Pass	6692	Pass
6693	Pass	6694	Pass	6695	Pass	6696	Pass
6697	Pass	6698	Pass	6699	Pass	6700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory