

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/044/26	Model No.: KMCRQ-5	Date: 09-06-2026
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 044/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 02151 To 2200	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 02151 To 2200 and removed from the Lot/Batch							
2151	Pass	2152	Pass	2153	Pass	2154	Pass
2155	Pass	2156	Pass	2157	Pass	2158	Pass
2159	Pass	2160	Pass	2161	Pass	2162	Pass
2163	Pass	2164	Pass	2165	Pass	2166	Pass
2167	Pass	2168	Pass	2169	Pass	2170	Pass
2171	Pass	2172	Pass	2173	Pass	2174	Pass
2175	Pass	2176	Pass	2177	Pass	2178	Pass
2179	Pass	2180	Pass	2181	Pass	2182	Pass
2183	Pass	2184	Pass	2185	Pass	2186	Pass
2187	Pass	2188	Pass	2189	Pass	2190	Pass
2191	Pass	2192	Pass	2193	Pass	2194	Pass
2195	Pass	2196	Pass	2197	Pass	2198	Pass
2199	Pass	2200	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory