

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/A50/RQ/043/26	Model No.: KMPRQ-10-50%	Date: 06-06-2026
Type and Capacity of Extinguisher	: KMPRQ-10-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMPRQ50%10 043/26	
Batch Quantity	: 20.00 Nos.	
Serial Numbers	: 00841 To 860	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00841 To 860 and removed from the Lot/Batch							
841	Pass	842	Pass	843	Pass	844	Pass
845	Pass	846	Pass	847	Pass	848	Pass
849	Pass	850	Pass	851	Pass	852	Pass
853	Pass	854	Pass	855	Pass	856	Pass
857	Pass	858	Pass	859	Pass	860	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory