

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/184/26	Model No.: KFARQ-6-50%	Date: 01-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 184/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 18301 To 18400 And 18305A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 18305A and removed from the Lot/Batch							
18301	Pass	18302	Pass	18303	Pass	18304	Pass
18305	Pass	18306	Pass	18307	Pass	18308	Pass
18309	Pass	18310	Pass	18311	Pass	18312	Pass
18313	Pass	18314	Pass	18315	Pass	18316	Pass
18317	Pass	18318	Pass	18319	Pass	18320	Pass
18321	Pass	18322	Pass	18323	Pass	18324	Pass
18325	Pass	18326	Pass	18327	Pass	18328	Pass
18329	Pass	18330	Pass	18331	Pass	18332	Pass
18333	Pass	18334	Pass	18335	Pass	18336	Pass
18337	Pass	18338	Pass	18339	Pass	18340	Pass
18341	Pass	18342	Pass	18343	Pass	18344	Pass
18345	Pass	18346	Pass	18347	Pass	18348	Pass
18349	Pass	18350	Pass	18351	Pass	18352	Pass
18353	Pass	18354	Pass	18355	Pass	18356	Pass
18357	Pass	18358	Pass	18359	Pass	18360	Pass
18361	Pass	18362	Pass	18363	Pass	18364	Pass
18365	Pass	18366	Pass	18367	Pass	18368	Pass
18369	Pass	18370	Pass	18371	Pass	18372	Pass
18373	Pass	18374	Pass	18375	Pass	18376	Pass
18377	Pass	18378	Pass	18379	Pass	18380	Pass
18381	Pass	18382	Pass	18383	Pass	18384	Pass
18385	Pass	18386	Pass	18387	Pass	18388	Pass
18389	Pass	18390	Pass	18391	Pass	18392	Pass
18393	Pass	18394	Pass	18395	Pass	18396	Pass
18397	Pass	18398	Pass	18399	Pass	18400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory