

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/239/26	Model No.: MARQ-6-50%	Date: 09-06-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 239/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 23801 To 23900 And 23805A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 23805A and removed from the Lot/Batch							
23801	Pass	23802	Pass	23803	Pass	23804	Pass
23805	Pass	23806	Pass	23807	Pass	23808	Pass
23809	Pass	23810	Pass	23811	Pass	23812	Pass
23813	Pass	23814	Pass	23815	Pass	23816	Pass
23817	Pass	23818	Pass	23819	Pass	23820	Pass
23821	Pass	23822	Pass	23823	Pass	23824	Pass
23825	Pass	23826	Pass	23827	Pass	23828	Pass
23829	Pass	23830	Pass	23831	Pass	23832	Pass
23833	Pass	23834	Pass	23835	Pass	23836	Pass
23837	Pass	23838	Pass	23839	Pass	23840	Pass
23841	Pass	23842	Pass	23843	Pass	23844	Pass
23845	Pass	23846	Pass	23847	Pass	23848	Pass
23849	Pass	23850	Pass	23851	Pass	23852	Pass
23853	Pass	23854	Pass	23855	Pass	23856	Pass
23857	Pass	23858	Pass	23859	Pass	23860	Pass
23861	Pass	23862	Pass	23863	Pass	23864	Pass
23865	Pass	23866	Pass	23867	Pass	23868	Pass
23869	Pass	23870	Pass	23871	Pass	23872	Pass
23873	Pass	23874	Pass	23875	Pass	23876	Pass
23877	Pass	23878	Pass	23879	Pass	23880	Pass
23881	Pass	23882	Pass	23883	Pass	23884	Pass
23885	Pass	23886	Pass	23887	Pass	23888	Pass
23889	Pass	23890	Pass	23891	Pass	23892	Pass
23893	Pass	23894	Pass	23895	Pass	23896	Pass
23897	Pass	23898	Pass	23899	Pass	23900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory