

HYDRO PRESSURE TEST

TC No.: HPT/CA2/SS/RQ/006/26	Model No.: KCASSRQ-2	Date: 12-06-2026
Type and Capacity of Extinguisher	: KCASSRQ-2-Kanex SS Clean Agent Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KCASSRQ2 006/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00051 To 60 And 55A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 55A and removed from the Lot/Batch							
51	Pass	52	Pass	53	Pass	54	Pass
55	Pass	56	Pass	57	Pass	58	Pass
59	Pass	60	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory