

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/025/26	Model No.: KFMRQ-45	Date: 12-05-2026
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 025/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01201 To 1250	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.1005A and which is removed from the batch (21st batch)							
1201	Pass	1202	Pass	1203	Pass	1204	Pass
1205	Pass	1206	Pass	1207	Pass	1208	Pass
1209	Pass	1210	Pass	1211	Pass	1212	Pass
1213	Pass	1214	Pass	1215	Pass	1216	Pass
1217	Pass	1218	Pass	1219	Pass	1220	Pass
1221	Pass	1222	Pass	1223	Pass	1224	Pass
1225	Pass	1226	Pass	1227	Pass	1228	Pass
1229	Pass	1230	Pass	1231	Pass	1232	Pass
1233	Pass	1234	Pass	1235	Pass	1236	Pass
1237	Pass	1238	Pass	1239	Pass	1240	Pass
1241	Pass	1242	Pass	1243	Pass	1244	Pass
1245	Pass	1246	Pass	1247	Pass	1248	Pass
1249	Pass	1250	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory