

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/088/26	Model No.: KFKHQ-6	Date: 07-06-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 088/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00871 To 880 And 875A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 875A and removed from the Lot/Batch							
871	Pass	872	Pass	873	Pass	874	Pass
875	Pass	876	Pass	877	Pass	878	Pass
879	Pass	880	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory