

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/090/26	Model No.: KFKHQ-6	Date: 09-06-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 090/26	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00891 To 900	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
891	Pass	892	Pass	893	Pass	894	Pass
895	Pass	896	Pass	897	Pass	898	Pass
899	Pass	900	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory