

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A90/RQ/022/26	Model No.: MARQ-6-90%	Date: 12-04-2026
Type and Capacity of Extinguisher	: MARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ90%6 022/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 02101 To 2200 And 2105A	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 2105A and removed from the Lot/Batch							
2101	Pass	2102	Pass	2103	Pass	2104	Pass
2105	Pass	2106	Pass	2107	Pass	2108	Pass
2109	Pass	2110	Pass	2111	Pass	2112	Pass
2113	Pass	2114	Pass	2115	Pass	2116	Pass
2117	Pass	2118	Pass	2119	Pass	2120	Pass
2121	Pass	2122	Pass	2123	Pass	2124	Pass
2125	Pass	2126	Pass	2127	Pass	2128	Pass
2129	Pass	2130	Pass	2131	Pass	2132	Pass
2133	Pass	2134	Pass	2135	Pass	2136	Pass
2137	Pass	2138	Pass	2139	Pass	2140	Pass
2141	Pass	2142	Pass	2143	Pass	2144	Pass
2145	Pass	2146	Pass	2147	Pass	2148	Pass
2149	Pass	2150	Pass	2151	Pass	2152	Pass
2153	Pass	2154	Pass	2155	Pass	2156	Pass
2157	Pass	2158	Pass	2159	Pass	2160	Pass
2161	Pass	2162	Pass	2163	Pass	2164	Pass
2165	Pass	2166	Pass	2167	Pass	2168	Pass
2169	Pass	2170	Pass	2171	Pass	2172	Pass
2173	Pass	2174	Pass	2175	Pass	2176	Pass
2177	Pass	2178	Pass	2179	Pass	2180	Pass
2181	Pass	2182	Pass	2183	Pass	2184	Pass
2185	Pass	2186	Pass	2187	Pass	2188	Pass
2189	Pass	2190	Pass	2191	Pass	2192	Pass
2193	Pass	2194	Pass	2195	Pass	2196	Pass
2197	Pass	2198	Pass	2199	Pass	2200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory