

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/141/26	Model No.: KFARQ-6-90%	Date: 02-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 141/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 14001 To 14100 And 14005A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 14005A and removed from the Lot/Batch							
14001	Pass	14002	Pass	14003	Pass	14004	Pass
14005	Pass	14006	Pass	14007	Pass	14008	Pass
14009	Pass	14010	Pass	14011	Pass	14012	Pass
14013	Pass	14014	Pass	14015	Pass	14016	Pass
14017	Pass	14018	Pass	14019	Pass	14020	Pass
14021	Pass	14022	Pass	14023	Pass	14024	Pass
14025	Pass	14026	Pass	14027	Pass	14028	Pass
14029	Pass	14030	Pass	14031	Pass	14032	Pass
14033	Pass	14034	Pass	14035	Pass	14036	Pass
14037	Pass	14038	Pass	14039	Pass	14040	Pass
14041	Pass	14042	Pass	14043	Pass	14044	Pass
14045	Pass	14046	Pass	14047	Pass	14048	Pass
14049	Pass	14050	Pass	14051	Pass	14052	Pass
14053	Pass	14054	Pass	14055	Pass	14056	Pass
14057	Pass	14058	Pass	14059	Pass	14060	Pass
14061	Pass	14062	Pass	14063	Pass	14064	Pass
14065	Pass	14066	Pass	14067	Pass	14068	Pass
14069	Pass	14070	Pass	14071	Pass	14072	Pass
14073	Pass	14074	Pass	14075	Pass	14076	Pass
14077	Pass	14078	Pass	14079	Pass	14080	Pass
14081	Pass	14082	Pass	14083	Pass	14084	Pass
14085	Pass	14086	Pass	14087	Pass	14088	Pass
14089	Pass	14090	Pass	14091	Pass	14092	Pass
14093	Pass	14094	Pass	14095	Pass	14096	Pass
14097	Pass	14098	Pass	14099	Pass	14100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory