

HYDRO PRESSURE TEST

TC No.: HPT/MOD15/A50/RQ/005/26	Model No.: KMPRQ-15-50%	Date: 12-06-2026
Type and Capacity of Extinguisher	: KMPRQ-15-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 15 Kg.	
Batch Number	: KMPRQ50%15 005/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00041 To 50	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00041 To 50 and removed from the Lot/Batch							
41	Pass	42	Pass	43	Pass	44	Pass
45	Pass	46	Pass	47	Pass	48	Pass
49	Pass	50	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory