

# HYDRO PRESSURE TEST

|                                   |                                                                           |                  |
|-----------------------------------|---------------------------------------------------------------------------|------------------|
| TC No.: HPT/MOD15/A50/RQ/006/26   | Model No.: KMPRQ-15-50%                                                   | Date: 12-06-2026 |
| Type and Capacity of Extinguisher | : KMPRQ-15-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 15 Kg. |                  |
| Batch Number                      | : KMPRQ50%15 006/26                                                       |                  |
| Batch Quantity                    | : 10.00 Nos.                                                              |                  |
| Serial Numbers                    | : 00051 To 60                                                             |                  |
| Month of Manufacturing            | : Jun/26                                                                  |                  |

| Sr. Nos.                                                           | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 00051 To 60 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 51                                                                 | Pass   | 52       | Pass   | 53       | Pass   | 54       | Pass   |
| 55                                                                 | Pass   | 56       | Pass   | 57       | Pass   | 58       | Pass   |
| 59                                                                 | Pass   | 60       | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**