

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/200/26	Model No.: KFARQ-6-50%	Date: 09-06-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 200/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 19901 To 20000 And 19905A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 19905A and removed from the Lot/Batch							
19901	Pass	19902	Pass	19903	Pass	19904	Pass
19905	Pass	19906	Pass	19907	Pass	19908	Pass
19909	Pass	19910	Pass	19911	Pass	19912	Pass
19913	Pass	19914	Pass	19915	Pass	19916	Pass
19917	Pass	19918	Pass	19919	Pass	19920	Pass
19921	Pass	19922	Pass	19923	Pass	19924	Pass
19925	Pass	19926	Pass	19927	Pass	19928	Pass
19929	Pass	19930	Pass	19931	Pass	19932	Pass
19933	Pass	19934	Pass	19935	Pass	19936	Pass
19937	Pass	19938	Pass	19939	Pass	19940	Pass
19941	Pass	19942	Pass	19943	Pass	19944	Pass
19945	Pass	19946	Pass	19947	Pass	19948	Pass
19949	Pass	19950	Pass	19951	Pass	19952	Pass
19953	Pass	19954	Pass	19955	Pass	19956	Pass
19957	Pass	19958	Pass	19959	Pass	19960	Pass
19961	Pass	19962	Pass	19963	Pass	19964	Pass
19965	Pass	19966	Pass	19967	Pass	19968	Pass
19969	Pass	19970	Pass	19971	Pass	19972	Pass
19973	Pass	19974	Pass	19975	Pass	19976	Pass
19977	Pass	19978	Pass	19979	Pass	19980	Pass
19981	Pass	19982	Pass	19983	Pass	19984	Pass
19985	Pass	19986	Pass	19987	Pass	19988	Pass
19989	Pass	19990	Pass	19991	Pass	19992	Pass
19993	Pass	19994	Pass	19995	Pass	19996	Pass
19997	Pass	19998	Pass	19999	Pass	20000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 SIHOR
 (GUJARAT)

Authorized Signatory