

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A2/A50/RQ/037/26      | Model No.: KFARQ-2-50%                                          | Date: 16-06-2026 |
| Type and Capacity of Extinguisher | : KFARQ-2-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg. |                  |
| Batch Number                      | : KFARQ50%2 037/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 03601 To 3700 And 3605A                                       |                  |
| Month of Manufacturing            | : Jun/26                                                        |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 3605A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 3601                                                         | Pass   | 3602     | Pass   | 3603     | Pass   | 3604     | Pass   |
| 3605                                                         | Pass   | 3606     | Pass   | 3607     | Pass   | 3608     | Pass   |
| 3609                                                         | Pass   | 3610     | Pass   | 3611     | Pass   | 3612     | Pass   |
| 3613                                                         | Pass   | 3614     | Pass   | 3615     | Pass   | 3616     | Pass   |
| 3617                                                         | Pass   | 3618     | Pass   | 3619     | Pass   | 3620     | Pass   |
| 3621                                                         | Pass   | 3622     | Pass   | 3623     | Pass   | 3624     | Pass   |
| 3625                                                         | Pass   | 3626     | Pass   | 3627     | Pass   | 3628     | Pass   |
| 3629                                                         | Pass   | 3630     | Pass   | 3631     | Pass   | 3632     | Pass   |
| 3633                                                         | Pass   | 3634     | Pass   | 3635     | Pass   | 3636     | Pass   |
| 3637                                                         | Pass   | 3638     | Pass   | 3639     | Pass   | 3640     | Pass   |
| 3641                                                         | Pass   | 3642     | Pass   | 3643     | Pass   | 3644     | Pass   |
| 3645                                                         | Pass   | 3646     | Pass   | 3647     | Pass   | 3648     | Pass   |
| 3649                                                         | Pass   | 3650     | Pass   | 3651     | Pass   | 3652     | Pass   |
| 3653                                                         | Pass   | 3654     | Pass   | 3655     | Pass   | 3656     | Pass   |
| 3657                                                         | Pass   | 3658     | Pass   | 3659     | Pass   | 3660     | Pass   |
| 3661                                                         | Pass   | 3662     | Pass   | 3663     | Pass   | 3664     | Pass   |
| 3665                                                         | Pass   | 3666     | Pass   | 3667     | Pass   | 3668     | Pass   |
| 3669                                                         | Pass   | 3670     | Pass   | 3671     | Pass   | 3672     | Pass   |
| 3673                                                         | Pass   | 3674     | Pass   | 3675     | Pass   | 3676     | Pass   |
| 3677                                                         | Pass   | 3678     | Pass   | 3679     | Pass   | 3680     | Pass   |
| 3681                                                         | Pass   | 3682     | Pass   | 3683     | Pass   | 3684     | Pass   |
| 3685                                                         | Pass   | 3686     | Pass   | 3687     | Pass   | 3688     | Pass   |
| 3689                                                         | Pass   | 3690     | Pass   | 3691     | Pass   | 3692     | Pass   |
| 3693                                                         | Pass   | 3694     | Pass   | 3695     | Pass   | 3696     | Pass   |
| 3697                                                         | Pass   | 3698     | Pass   | 3699     | Pass   | 3700     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**


 SIHOR  
 (GUJARAT)

**Authorized Signatory**