

# HYDRO PRESSURE TEST

|                                   |                                                                        |                  |
|-----------------------------------|------------------------------------------------------------------------|------------------|
| TC No.: HPT/F45/RQ/031/26         | Model No.: KFMRQ-45                                                    | Date: 22-06-2026 |
| Type and Capacity of Extinguisher | : KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr. |                  |
| Batch Number                      | : KFMRQ45 031/26                                                       |                  |
| Batch Quantity                    | : 51.00 Nos.                                                           |                  |
| Serial Numbers                    | : 01501 To 1550 And 1505A                                              |                  |
| Month of Manufacturing            | : Jun/26                                                               |                  |

| Sr. Nos.                                                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-----------------------------------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on Cylinder Sr.No.1505A and which is removed from the batch (31st batch) |        |          |        |          |        |          |        |
| 1501                                                                                          | Pass   | 1502     | Pass   | 1503     | Pass   | 1504     | Pass   |
| 1505                                                                                          | Pass   | 1506     | Pass   | 1507     | Pass   | 1508     | Pass   |
| 1509                                                                                          | Pass   | 1510     | Pass   | 1511     | Pass   | 1512     | Pass   |
| 1513                                                                                          | Pass   | 1514     | Pass   | 1515     | Pass   | 1516     | Pass   |
| 1517                                                                                          | Pass   | 1518     | Pass   | 1519     | Pass   | 1520     | Pass   |
| 1521                                                                                          | Pass   | 1522     | Pass   | 1523     | Pass   | 1524     | Pass   |
| 1525                                                                                          | Pass   | 1526     | Pass   | 1527     | Pass   | 1528     | Pass   |
| 1529                                                                                          | Pass   | 1530     | Pass   | 1531     | Pass   | 1532     | Pass   |
| 1533                                                                                          | Pass   | 1534     | Pass   | 1535     | Pass   | 1536     | Pass   |
| 1537                                                                                          | Pass   | 1538     | Pass   | 1539     | Pass   | 1540     | Pass   |
| 1541                                                                                          | Pass   | 1542     | Pass   | 1543     | Pass   | 1544     | Pass   |
| 1545                                                                                          | Pass   | 1546     | Pass   | 1547     | Pass   | 1548     | Pass   |
| 1549                                                                                          | Pass   | 1550     | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



**Authorized Signatory**